

# RURAL ELECTRIFICATION AGENCY

HEAD OFFICE  
Megawatt House  
44 Samora Machel Avenue, Harare  
P.Bag 250A, Harare  
[Tel:04-734734,734355,734732,734347,708110](tel:04-734734,734355,734732,734347,708110)  
Fax: 04-707667, 708067



OUR REF:.....

YOUR REF:.....

WHEN CALLING WITH REFERENCE TO THIS  
~~LETTER PLEASE REFER~~ FOR

30 August 2021

Dear Bidder

## AMENDMENTS/CLARIFICATIONS FOR TENDER : REF/INTER/05/08/2021:SUPPLY AND DELIVERY OF VARIOUS TRANSFORMERS.

Reference is made to the above named tender.

In terms of section 41(4) of the Public Procurement and Disposal of Public Assets Act(22:23),the Rural Electrification Fund (REF) reserves the right to amend the bidding document at any time before tender closing. These amendments/clarifications shall be used for purposes of tender evaluation.

### QUESTION BY A BIDDER

May you kindly provide clarification on losses mentioned on page 34 of 54, these seem to be wrongly mentioned against capacities. Losses w.r.t capacities are wrong, in technical details losses for 25KVA mentioned are much more than 50KVA.Kindly clarify losses requirement.

### RESPONSE BY REF

Bidders are advised that the figures shown on the Technical Guarantee schedules in the Bidding Document provided are not exact figures. Those figures are just examples. The bidder has to fill in the technical guarantee schedules using HIS OWN MANUFACTURER TYPE GUARANTEED VALUES.

---

**Board Members :** Eng J.M Mberi (Chairman), L.L Dhlamini (Ms), (Deputy Chairperson), F.A Chikovo, C. Shumba, F.S.Mbetsa, J.T.Jaji, C .Chitiyo (Mrs), C.Ndarukwa, P.Makora (Mrs), W.Sibanda, M. Musabayana (Mrs)  
J. Mashamba (Chief Executive)

Similar transformers of same size and ratings give out different no load loss figures because of the type of core materials used especially the materials used in the core. The Bidders' technical guarantee values are used for technical evaluation among other parameters.

Please be advised accordingly.

Yours Faithfully



**ENG. J.V MASHAMBA  
CHIEF EXECUTIVE OFFICER**