

# RURAL ELECTRIFICATION FUND

## HEAD OFFICE

Megawatt House

44 Samora Machel Avenue, Harare

P. Bag 250A, Harare

Tel: +263 242 791725/29, +263772134806/9;

+2638611376849



Magetsi Kumusha / Amagetsi Ekhaya

OUR REF:.....

YOUR REF:.....

WHEN CALLING WITH REFERENCE TO THIS  
LETTER PLEASE ASK FOR

24 May 2022

Dear Bidder

### TENDER CLARIFICATION: REF/DOM/12/05/2022-CONSTRUCTION OF A PERIMETER WALL AND A GUARDROOM AND REF CENTRAL STORES.

Reference is made to the above named tender.

In terms of section 41(4) of the Public Procurement and Disposal of Public Assets Act (22:23), the Rural Electrification Fund (REF) reserves the right to amend the bidding document at any time before tender closing. These amendments/clarifications shall be used for purposes of tender evaluation.

Bidders are advised of the following amendments/clarifications for the above named tender:

- The height of the perimeter wall (Durawall) must be 3m high. Bidders must state the height of the perimeter wall in their bid documents.
- The bricks to be used shall be industrial bricks (red). Bidders must state that the bricks to be used shall be as stated.
- Kindly ignore the issue of Lots mentioned in the Bidding Document. The tender is not divided in Lots.

The remaining tender terms and conditions remain unchanged.

Yours Sincerely

.....  
ENG. J.V MASHAMBA  
CHIEF EXECUTIVE OFFICER